# General Specifications

# Model NTPC020 **E**xaquantum Down Time Analysis

# 

Planned production is often compromised by unplanned Downtime incidents and sub-optimal production rates that are not quantified in terms of Time, Rate Loss and the associated Reasons. Without this quantifiable information there is no way to consistently identify potential Downtime causes and to assign activities to make the necessary improvements avoiding future lost production.

# SOLUTION

Exaquantum Down Time Analysis (Exaquantum/DTA; hereafter referred to as 'DTA') is Yokogawa's solution.

Based on the need to log and track unplanned equipment Downtime, DTA automatically captures plant data to enable Downtime analysis to be carried out.

The system records times when plant equipment is not running ('Downtimes') and production figures which are less than the Maximum Sustainable Production Rate ('Rate Losses'). Reasons can then be assigned to these events to add context. The resulting statistics are integral to the operational decision making process with a view to minimizing plant loss and maximizing future production.

# BENEFITS

- Continuous plant availability improvement through increased awareness of Downtime and Rate Loss within the operating process and equipment dynamics
- Prioritized maintenance by identifying the causes and effects of Production Loss
- Shared best practices between plant Production Units to reduce potential Downtime
- Inaccuracies removed through automated data collection, verified and enhanced with manual input to provide accurate information for improved decision making
- Detailed standard reports plus the ability to create custom reports allowing information to be exposed that is normally not available
- Reports are available on demand or scheduled as required. Distribution via email is supported making information available in a timely fashion to decision makers
- Access to Downtime and Rate Loss information is provided via a web interface.

# KEY FEATURES

- Downtime Loss (Hours) is continuously collected and registered for each Plant Unit
- Rate Loss is calculated and registered on a daily basis for each Plant Unit at the end of each production day
- Rate Losses can be translated into equivalent Downtime Losses and vice versa.



ome Downtime Events Rat	e Loss Events Reports	_	_		Settings He
Latest Downtime Eve	nts			Availability KPI for la	ist 30 days
Piert	Time Down	Time Up	Loss	Plant	Availability
AME, Train A	17 Aug 2010 21-06-52	17 Aug 2010 22:33:52	1.45 hours	AMB Train A	85.14%
SAR Train C	17 Aug 2010 19-33-52	17 Aug 2010 23-44-52	4.16 bours	PARTruin A	92.01 %
SARTrain B	17 Aug 2010 01:35:52	17 Aug 2010 07:59:52	6.40 hours	PARTrait B	91.16.%
PARTrain B	16.Aug 2010 19:07:52	16 Aug 2010 23:58:52	4.853 sure	EARTrais C	91.70 %
AMB, Train, A.	16 Aug 2010 15-35-52	17 Aug 2010 01/26/92	9.85 hours	SAR Train 8	92,42 %
PARTrain A	15 Aug 2010 14 26 52	15 Avg 2010 21:56:32	7.50 hours	SARTrain AUbilities	92.54 %
AMR.Train A	15 Aug 2010 13:08:52	15-Aug 2010 15:59-52	2.85 hours	Downtimes KPI for la	ist 30 days
PAD.Train B	15 Aug 2010 04 23 52	15 Aug 2010 11:46:52	7.38 hours	Press	and the second second
SARTrain AUclities	15 Aug 2010 02:14:52	15 Aug 2010 07:21:52	5.12 hours	AME THE A	85.72 have
PAR.Train B	13 Aug 2010 00:50:52	13 Aug 2010 01:08:32	0.30 hours	DAD Train &	6475 hours
atest Rate Loss Ever	ote			PARTrain B	63.67 hours
atest hate 2033 Even	ites			SARTINI C	5973 hears
Flast	Duts/Time		Loss	SAR Train 8	54.57 hours
PAA Train B	17 Aug 2010-00-00-00		97 82+8	SARTrain AUGIStee	53.72 hours
SAR Train A Utilities	17 Aug 2010 00:00:00		60 2548	Bate Lass KDT for las	20 Jan
SARTINE	14 Aug 2010 00:00:00		144 5048	Rate Loss KP1 for las	t 30 days
SAR TINK C	16 Aug 2010 00:00:00	14 Aug 2010 00:00:00		Plant	Loss
SAN TRACAULTURE	14 ~42010 00 00 00	16 Aug 2010 00:00:00		SAR Train B	1646 ton
B PWW/178W B	12 mag 2010 00:00:00	15 Aug 2010 00:00:00		SARTING C	1520 to 4
BAR Treix C	13 Aug 2010 00:00		8935+8	SARTrain AUblidge	1177 to 4
BART/BRC	14 Aug 2010 00:00:00		1 0049	AMRTHERA	062114
PARTrain B	14 Aug 2010 00:00:00		02 6842	PARTrain B	781104
SARTryin AUtilities	14 Aug 2010 00:00:00		85 5144	PARTosis A	274 1044

F02E.ai



#### ■ INTRODUCTION

A Plant will have one or more Production Units that are expected to be in constant production. Any interruption to production is considered Downtime, with an associated Loss.

Downtime Loss is automatically collected and registered in DTA on a per-Unit basis. Downtime Loss is a measure of production loss when a Production Unit is Down, measured in time.

Rate Loss is a measure of production loss when the Production Unit is Up, calculated in Units/Hour. Rate Loss is the loss of production due to sub-optimal operating conditions.

Standby is a measure of the time a piece of equipment is ready to run but is prevented from doing so by another piece of equipment being Down. The collection of standby data is optional and is available for collection on any equipment within the plant hierarchy.

Downtime Loss (Hours) can be translated into an equivalent Units/H, and Rate Loss (Units/H) can be translated into Hours allowing total loss to be represented by either Hours or Units/H.

Plant and Reason hierarchies are used for both selection, aggregation and reporting purposes.

# CAPABILITIES

Assignment of Downtime and Rate Loss Reasons The assignment of Reasons to Losses can be made by one or more users.

There may be multiple Reasons associated with each Downtime occurrence and therefore the ability to weight Reasons is provided. For example, Reason A may be responsible for 60% of the Downtime and Reason B responsible for 40% of the Downtime. The weighting can be entered as either a percentage of the total Downtime or an actual time duration. If a day boundary is crossed these weightings will get allocated pro-rata for each day.

To aid in the allocation of Reasons to Downtimes, a record of the 'First Out Stop' equipment and cause may be collected and linked to the Downtime event.

There may be multiple Reasons associated with each Rate Loss occurrence and therefore the ability to assign percentage allocations to each Reason is provided. For example, Reason A may be responsible for 20% of the material loss and Reason B responsible for 80% of the material loss.

#### Web User Interface

Web based access means there is no need for specific client software installation.

An Overview Screen provides a summary of the:

- Latest Downtime Events
- Latest Rate Loss Events
- · Availability KPI for the last 30 days
- Downtime KPI for the last 30 days
- Rate Loss KPI for the last 30 days
- · OEE KPI for the last 30 days

In addition, custom KPI's can be engineered and added to the overview screen and summary reports.

#### Rate Loss

The Rate Loss Events are presented as a user selectable filtered view with additional drilldown for detailed information. Selecting a Rate Loss Event provides the user with the details of the event along with associated Reasons. Multiple Rate Loss Reasons can be assigned and edited for a Rate Loss event.



#### **Downtime Events**

The Downtime Events are presented as a selectable filtered view with additional drilldown for detailed information. Selecting a Downtime Event provides further details and any assigned Reasons.

Multiple Downtime Reasons can be assigned to a Downtime Event. The PCS Stop cause and PCS Stop equipment, if configured for collection, can also be viewed.



#### **Process Unit Summary Report**

Downtime, Rate Loss and Total Availability for a requested period are aggregated up through the units of the Plant Hierarchy. The Summary Report is able to show this information against the expanded Plant Hierarchy.

Selection of any Plant Hierarchy node generates a Reason Classification Report for the selected node and period of interest. This allows users to explore detailed information using drilldown through different time periods, Plant Hierarchy and Reason Hierarchy to identify cases that are the most deserving of corrective action:

#### **Downtime and Rate Loss Ranking Reports**

The Downtime Equipment Ranking and Rate Loss Equipment Ranking Reports split ranking down into combinations of equipment and allocated reason.

From the Downtime, Rate Loss, Downtime Equipment, or Rate Loss Equipment Ranking reports further drilldown is possible to a detailed event report, showing the individual Downtime and Rate Loss events that contributed to the totals in the ranking report.

#### **Reason Classification Report**

The Downtime and Rate Loss associated with Reasons are aggregated up through the nodes of the Reason Hierarchy. The Reason Classification Report displays this information against the expanded Reason Hierarchy.

From the Reason Classification Report, four more reports can be drilled down to; Downtime Ranking, Rate Loss Ranking, Downtime Equipment Ranking, and Rate Loss Equipment Ranking, with worst offending Reasons listed in contribution order.

	Reason Classification
Downtime and Rate Shortfall losse	s are mapped to Reason. Both loss types are represented together as Time
in hours and Product loss in (UNIT	). The Reason Hierarchy maps Reason Detail to Reason, Responsible, and
Linked Plant. Select a box below t	o navigate to Ranking Reports.

01

...

. .

Downtime Ranking	Downtime Equipment Ranking			
Rate Loss Ranking	Rate Loss Equipm			
Reason Hierarchy:-	Downtime	Rate Loss	Production Loss	
Reason Set Responsible Reason Group Reason	(hours)	(UNIT)	As Time (hours)	As Production (UNIT)
AMP	198.33	14400	212.73	212733.33
Maint_Planned	16.93	1200	18.13	18133.33
Electrical	5.1		5.1	5100
Daily	.5		.5	500
Weekly	1.43		1.43	1433.33
Monthly	1.5		1.5	1500
Other	1.67		1.67	1666.67
E Mechanical	6.33	600	6.93	6933.33
Daily	1.5		1.5	1500
Weekly	1.33		1.33	1333.33
Monthly	1.83	600	2.43	2433.33
Other	1.67		1.67	1666.67
Instrument	5.5	600	6.1	6100
Daily	1		1	1000
Weekly	1.17	600	1.77	1766.67
Monthly	1.17		1.17	1166.67
Other	2.17		2.17	2166.67
Maint_Unplanned	49.17	4200	53.37	53366.67
Electrical	14.33	600	14.93	14933.33
DCS fault	1.5		1.5	1500
Drive Train	1.17		1.17	1166.67
Excitor Faulty	1.33	0.0	1.33	1333.33
Gland Flow Low	1.33		1.33	1333.33
Laual Indicator Fault	2.67		2.67	2666 67

#### **Custom Reports**

Exaquantum/DTA's Downtime and Rate Loss data and any assigned Reason data can be accessed from Microsoft Excel. Administrators can also create new reports in SQL Server Report Builder to supplement the standard reports. Administrator created Custom reports can be scheduled for emailing.

#### **OPC DA and HDA Client Interfaces**

Exaquantum/DTA collects production data from OPC DA 2.05a and HDA 1.1 servers, such as Yokogawa's 'Exaopc' or OPC servers provided by other suppliers.

#### **Operational Benefits**

Exaquantum/DTA can provide a number of operational benefits, including:

- Productivity improvement initiatives by comparing plant production lines and shifts
- Exposing areas of concern in the operational health of different parts of the plant
- Improving operations by setting appropriate targets or priorities
- Consolidated view of Downtime occurrence relationships
- Historical information access allowing comparison with past plant performance allowing judgments to be made on the effectiveness of upgrades.

#### **Business Benefits**

Exaquantum/DTA can provide a number of business benefits, including:

- · Increased production and asset utilization
- · Improved planning and scheduling
- · Reduced delivery times to customers
- A culture of continuous improvement based upon an effective and formalized Downtime Analysis and Reporting System.



# HARDWARE AND SOFTWARE REQUIREMENTS

#### **Minimum Hardware and Software Specifications**

Component	Minimum Hardware Specifications
Exaquantum/DTA Server	As listed in the Exaquantum R3.01 GS 36J04A10-01E for an Exaquantum Server
Exaquantum/DTA Web Server	As listed in the Exaquantum R3.01 GS 36J04A10-01E for an Exaquantum Web Server
Exaquantum/DTA Web Clients	As listed in the Exaquantum R3.01 GS 36J04A10-01E for an Exaquantum Web Client

Component	Software Specifications
Exaquantum/DTA Server	As listed in the Exaquantum R3.01 GS 36J04A10-01E for an Exaquantum Server
Exaquantum/DTA Web Server	As listed in the Exaquantum R3.01 GS 36J04A10-01E for an Exaquantum Web Server
Exaquantum/DTA Web Clients	As listed in the Exaquantum R3.01 GS 36J04A10-01E for an Exaquantum Web Client

If DTA will be installed on a different version of Exaquantum, please contact Yokogawa for assistance.

# MODELS AND SUFFIX CODES

## Exaquantum/DTA Product

		Description
Model	NTPC020	Exaquantum/DTA Product
	-S	Basic Software License
	1	New Order (with Media)
Suffix Codes	1	English version
	-SV□	Enter the number of Exaquantum/ DTA Server Licenses (1 - 9)
	-WC□	Enter the number of per-seat Exaquantum/DTA Web Client Licenses (1 - 9)

## Maintenance Service for Exaquantum/DTA

		Description
Model	NTMC020	Maintenance Service for Exaquantum/DTA
Suffix Codes	-S	Annual Contract
	1	Always 1
	1	Always 1
	-SV□	Enter the number of Exaquantum/ DTA Server Licenses (1 - 9)
	-WC□	Enter the number of New per-seat Exaquantum/DTA Web Client Licenses (1 - 9)

# ORDERING INFORMATION

Specify model and suffix codes.

# TRADEMARKS

- Exaquantum, Exaopc and CENTUM are registered trademarks of the Yokogawa Electric Corporation.
- Other company names and product names mentioned in this General Specification are registered trademarks of their respective companies.